



Guam Memorial Hospital Authority Aturidåt Espetåt Mimuriåt Guåhan



850 GOV. CARLOS CAMACHO ROAD
OKA, TAMUNING, GUAM 96913
TEL: 647-2444 or 647-2330
FAX: (671) 649-0145

February 20, 2019

**AMENDMENT #2
FOR
GMHA IFB 004-2019**

**Removal and Replacement of Two (2) Air Handling Units @ 1st Floor Lobby Entrance and
Physical Therapy Department**

TO: All prospective bidders,

This Amendment is being issued to clarify the following:

1) Vendor: JMI-Edison

1. Is this bid locally or federally funded?
2. Are we able to schedule another site visit?

GMHA Response:

1. **IFB 004-2019 is locally funded.**
2. **Third On-Site Visit/Inspection: Scheduled for Thursday, February 21, 2019 @ 10:00am in the Facilities Maintenance Office.**

2) Vendor: JRN Air Conditioning & Refrigeration

1. On the IFB 004-2019 page 24 of 26, Equipment Schedule, the inside Air CFM is 3,705(Approximately 10T); Outside Air CFM is 2,615 respectively. The data does not reflect the Total Load of 270-440 BTU/HR. (Approximately 22.5T) kindly confirm which data to follow.

GMHA Response:

1. **Please see attached Data Chart for Physical Therapy AHU.
Physical Therapy AHU-Existing Model & Capacity:
-Brand: CARRIER
-Cap.: 5 Ton**

If any other questions/clarifications please send via telefax addressed to Mrs. Lillian Perez-Posadas, RN, MN.



Dolores F. Pangelinan,
Hospital Supply Management Admin.

Acknowledgment of Receipt: Return acknowledgment to fax number 649-3640

Company

Print Name

Signature Date