



Guam Memorial Hospital Authority Aturidåt Espetåt Mimuriåt Guåhan



850 GOV. CARLOS CAMACHO ROAD
OKA, TAMUNING, GUAM 96913
TEL: (671) 647-2444 or 647-2330
FAX: (671) 649-0145

AMENDMENT #5 GMHA IFB 003-2020 REMOVAL AND REPLACEMENT OF THE 1.6 MW GENERATOR #2

This amendment is in response to a clarification from JMI Guam.

QUESTION #1. We would like to request for another 2 weeks' extension for the bid and deadline of questions for GMHA IFB 003-2020 – Removal and Replacement Generator Unit No. 2.

RESPONSE: Two (2) week extension is granted. The current submission date as reads: Submission on December 16, 2019 on or before 10:00 am, with opening date on December 16, 2019 at 10:30 am.

Submission date is now changed to read as: packets are due on or before 10:00 am on December 30, 2019 with bid opening at 10:30 am, on December 30, 2019.

QUESTION #2: We wanted to follow up on the as built previously requested on Amendment #4. We will need this in order to provide an estimate for the removal and installation.

RESPONSE: GMHA is unable to locate the as Built Plan for generator shelter. However, vendor/bidder must be able to support the structure three times it's weight.

QUESTION #3: Is the existing muffler shall be reuse and or refit to the new Genset exhaust.

RESPONSE: It should be a new muffler to fit and be compatible to new generator being offered.

QUESTION #4: As per GMHA request for a breakdown of duration for each that sums up to 300 days.

RESPONSE: Bid completion of 180 days has been changed to 300 days.

Please acknowledge receipt of this amendment by signing and sending back to Materials Management by Fax at 649-3640 or email to materials.mgmt@gmha.org.

If you have any questions, please feel free to address your letter to Lillian Perez-Posadas MN, RN, and fax to the Materials Management Office at 649-3640 or email to the materials.mgmt@gmha.org.

Sincerely;

DOLORES PANGELINAN
Hospital Materials Management Department

ACKNOWLEDGMENT:

PRINT NAME

SIGNATURE

DATE